

ADDENDUM NO. 5

Walla Walla Life Flight Network Hangar Project December 7, 2023

Bid Opening Date: December 14, 2023 @ 2:00 p.m. PST

TO ALL PLANHOLDERS:

This Addendum provides changes to the plans (drawings) and specifications for the **Walla Walla Life Flight Network Hangar Project**. This Addendum shall be included in the Proposal and, when closing the Contract, will be a part thereof. Any changes made by this Addendum to said plans (drawings) and specifications offset only the portion of the plans (drawings), words or paragraphs specifically mentioned herein, and the balance of the plans (drawings) and/or specifications remain in full force. It is the responsibility of all bidders to conform to this addendum.

This Addendum consists of a total of 1 page.

All bidders shall acknowledge receipt and acceptance of this Addendum on the Bid Form Packet which is submitted with the bid.

The selected contractor will be responsible for having one of their staff obtain the air operations badge for security, for work when the airfield security fence is opened to allow some of the work of this contract. The Port will not charge a fee for getting this training and badge.

A. SPECIFICATIONS

1. Revise Section 11100, 1.01, A, add sentence: "If the listed equipment is no longer available please refer to Section 15001, 1.1, F, 4 for description of item and contractor to select current similar model meeting the same description. In addition, use the following criteria for selection: a) Refrigerator – has an icemaker and is a large capacity; b) Range – Glass cooktop. No coil burners; c) Microwave w/ vent – Has a vent that is vented to the exterior or the building; d) Dishwasher – Normal size; e) Washer & Dryer – Front Loads, Stacked (Washer on the bottom, Dryer on top) Large Capacity."
2. Revise 15001 Mechanical/Plumbing Design/Build Requirements, Add: 1.1, F, 2, add sentence: "The lists below are for general information. It will be up to the contractor to provide a complete system complying with State of Washington codes. This may include requirements for ERV's and heat recovery units. Contractor's responsibility is to provide a permit approved system."

B. DRAWINGS

1. Revise: A0.2 Schedules and Finishes, revise Finish Schedule, Key 2, to add: "or Patcraft North Ridge LVT 6" Model 1207V-02700, or equal."
2. Revise: A1.1 Ceiling Notes, Big Ass Ceiling Fan 8'-0" diameter, Add: "Powerfoil 8, or approved equal."

Attachments: None

END OF ADDENDUM NO. 5 by Aron Faegre